

Certificate of Conformity

No 1772/2011

Inspecta Latvia has granted this certificate as proof that

Double leaf fire resisting doorsets made of aluminium profile systems ADS80 FR60 (producer „Schüco International KG”); with maximum dimensions 2858 mm x 2880 mm x 80mm and with fire resistant glazing (active door leaf: 1280mm x 2340mm x 23mm; passive door leaf 1280mm x 2340mm x 23mm),

placed on the market by:

„GK Holding” Ltd.

„Lauki”, Ādažu nov., Stapriņi, LV-2164, Latvia; reg. No. 40103322649

AND PRODUCED IN THE FACTORY: „GK Holding” Ltd., „Lauki”, Ādažu nov., Stapriņi, LV-2164.

CERTIFIED IN COMPLIANCE WITH:

Testing results according to standard LVS EN 13501-2 („IBS Institut für Brandschutztechnik und Sicherheitsforschung” fire resistance test report No. 06050206 (08.10.2010.))

Classification of product according to standard:

LVS EN 13501-2:2008 “Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services”: fire resistance class E60/EI₁30/EI₂60.

Certificate remains valid as long as the conditions laid down in the above mentioned standard, related provisions, the manufacturing conditions in the factory and the product specification of the certified type are not modified significantly.

Issue date: 29.03.2011.

Martins Maskavs, Certification Manager

CEOC
INTERNATIONAL

European Confederation of Organisations
for Testing, Inspection and Certification

