

## Certificate of Conformity

**NO 1787/2011**

Inspecta Latvia has granted this certificate as proof that

**Single leaf fire resisting doors with glazing  
made of aluminium profile system „CS 68-FP”  
(profile system manufacturer: „Reynaers Aluminium NV”  
(Old Liersebaan 266, 2570 Duffel, Belgium)),**

placed on the market by:

### **„GK Holding” Ltd.**

"Lauki", Ādažu nov., Stapriņi, LV-2164, Latvia; reg. No 40103322649

AND PRODUCED IN THE FACTORY: „GK Holding” Ltd., "Lauki", Ādažu nov., Stapriņi, LV-2164

CERTIFIED IN COMPLIANCE WITH:

Testing results according to standard EN 13501-2 (*WarringtonFireGent* fire resistance test report  
No 11233C (30 October, 2005))

Classification of product according to standard:

**LVS EN 13501-2:2008 “Fire classification of construction products and building  
elements - Part 2: Classification using data from fire resistance tests, excluding  
ventilation services”: fire resistance class E30/ EI<sub>1</sub> 30/EI<sub>2</sub> 30/ EW30.**

Certificate remains valid as long as the conditions laid down in the above mentioned standard,  
related provisions, the manufacturing conditions in the factory and the product specification of the  
certified type are not modified significantly.

Issue date: 07.04.2011.

  
Martins Maskavs, Certification Manager

**CEOC**  
INTERNATIONAL

European Confederation of Organisations  
for Testing, Inspection and Certification



This certificate is issued on 1 (one) page.