

## Certificate of Conformity

NO 1773/2011

Inspecta Latvia has granted this certificate as proof that

**Curtain walling made of aluminium profile systems FW 50+BF (producer „Schüco International KG”) with fire resistant glazing  
(Dimensions 2600 mm x 1176 mm x 15mm; 2600mm x 1400mm x 15mm;  
1276mm x 2574mm x 32mm),**

placed on the market by:

### „GK Holding” Ltd.

"Lauki", Ādažu nov., Stapriņi, LV-2164, Latvia; reg. No 40103322649

AND PRODUCED IN THE FACTORY: „GK Holding” Ltd., "Lauki", Ādažu nov., Stapriņi, LV-2164

CERTIFIED IN COMPLIANCE WITH:


Testing results according to standard LVS EN 13501-2 LVS EN 13501-2 („IBS Institut für Brandschutztechnik und Sicherheitsforschung” fire resistance test report No 03062305-1 (28.12.2003.))

Classification of product according to standard:

**LVS EN 13501-2:2008 “Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services”: fire resistance class EI30.**

Certificate remains valid as long as the conditions laid down in the above mentioned standard, related provisions, the manufacturing conditions in the factory and the product specification of the certified type are not modified significantly.

Issue date: 29.03.2011.

  
Martins Maskavs, Certification Manager

**CEOC**  
INTERNATIONAL

European Confederation of Organisations  
for Testing, Inspection and Certification

